



NOTES:

1. ALL FABRICATED METAL PARTS SHALL BE NEW STRUCTURAL, ASTM A-36 STEEL, AND BE HOT-DIPPED GALVANIZED AFTER FABRICATION.
2. ALL POURED IN PLACE CONCRETE SHALL HAVE A 28 DAY STRENGTH OF 3000 P.S.I. AND A SLUMP OF 2" TO 4".
3. INSTALL STRUCTURE ON MINIMUM OF 8" OF 3/4"- 0" OR 1"- 0" COMPACTED BASE MATERIAL.
4. 72" MAXIMUM ALLOWED WITH CITY APPROVAL TO AVOID CONFLICTS WITH EXISTING UTILITIES.
5. MINIMUM SUMP DEPTH IS 24" TYPICAL, 36" MINIMUM SUMP DEPTH IF FITTED WITH A SNOUT.



City of Lake Oswego
Engineering Division
Erica Rooney, P.E. City Engineer

INLET CATCH BASIN (CG-48)

SD5-03B

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER