



**NOTES:**

- 1) CORP. STOP, COPPER TUBING, CURB STOP, BRASS PIPING, GALV. PIPING & FITTINGS TO EQUAL SIZE OF AIR VALVE INLET/OUTLET.
- 2) CORP. STOP AND CURB STOP SHALL BE FLARED FITTINGS.
- 3) ENSURE ACCESS TO CURB STOP.



City of Lake Oswego  
Engineering Division

Erica Rooney, P.E. City Engineer

**AIR VALVE ASSEMBLY**

**W3-01A**

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER