



NOTES:

1. TOP OF PERFORATED SECTION MUST BE BELOW THE ELEVATION OF THE LOWEST FINISHED FLOOR.
2. DRAIN PIPE MUST HAVE A MIN DIAM OF 6-INCHES
3. CATCHBASIN MUST BE SUMPED A MINIMUM OF 1.5' FOR SINGLE FAMILY RESIDENTIAL APPLICATIONS. MIN 3' SUMP FOR ALL OTHER APPLICATIONS.
4. DRAINROCK (1- 1/2" - 3/4") MUST COMPLY WITH AASHTO#4
5. COMPACTED CRUSHED ROCK MUST COMPLY WITH AASHTO #68
6. LOCKABLE MAINTENANCE ACCESS IS REQUIRED FOR ALL APPLICATIONS.
7. CONSTRUCTION VEHICLES AND MATERIAL STORAGE PROHIBITED WITHIN 10' OF DRYWELL LOCATION. LOCATION MUST BE SURROUNDED BY PROTECTIVE CONSTRUCTION FENCING.
8. SETBACKS: 5' FROM SEASONALLY HIGH GROUNDWATER TABLE, 10' FROM EDGE OF DRAINROCK TO FOUNDATION, 5' FROM EDGE OF DRAINROCK TO PROPERTY LINE
9. REGISTRATION WITH DEQ IS REQUIRED FOR ALL FACILITIES RECEIVING MORE THAN SINGLE FAMILY RESIDENTIAL ROOF RUNOFF.

DRAWING ADAPTED FROM CITY OF GRESHAM



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

PRIVATE DRY WELL

SD9-04

EFFECTIVE DATE: SEPTEMBER 14, 2020 NOT TO SCALE

DRAWING NUMBER