



NOTES:

1. MAX SLOPE OF 6%.
2. 1 TO 3-INCH LEVELING COURSE MUST COMPLY WITH AASHTO #8.
3. 3-INCH CHOKER COURSE ($\frac{3}{4}$ " TO $\frac{1}{2}$ ") MUST COMPLY WITH ODOT SPECIFICATION 00430.11.
4. STORAGE LAYER MUST COMPLY WITH AASHTO #57. DEPTH MUST BE A MIN OF 6 INCHES AND A MAX OF 3'. FACILITIES USING PRESCRIPTIVE SIZING MUST USE A 6-INCH STORAGE LAYER.
5. ROCK BETWEEN PAVERS MUST BE WASHED CRUSHED ROCK ($\frac{3}{4}$ " TO 0") COMPLYING WITH ODOT SPECIFICATIONS 00430.11
6. NON-WOVEN GEOTEXTILE MUST COMPLY WITH ODOT SPECIFICATION 02320.20, TABLE 1, TYPE 2.
7. MINIMIZE CONSTRUCTION VEHICLES AND MATERIAL STORAGE IN PAVER LOCATION. RAKE SUBGRADE TO A DEPTH OF 1.5' BEFORE CONSTRUCTION.
8. PERFORATED PIPES ARE PROHIBITED.

ADAPTED FROM CLEAN WATER SERVICES



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

PERMEABLE PAVERS

SD9-10

EFFECTIVE DATE: SEPTEMBER 14, 2020 NOT TO SCALE

DRAWING NUMBER