



**NOTES:**

1. BRANCH SPACING AND NUMBER OF BRANCHES TO BE CALCULATED BASED ON FLOWS FROM IMPERVIOUS AREA BEING TREATED.
2. FITTINGS TO BE SAME MATERIAL AS PERFORATED PIPE.
3. PIPE MUST BE 4 TO 6-INCH PERFORATED PIPE THAT MEETS ODOT SPECIFICATION 02415.50. SLOTS MUST BE PREFABRICATED. 6-INCH PIPE REQUIRED FOR PUBLIC FACILITIES.

ADAPTED FROM CLEAN WATER SERVICES



City of Lake Oswego  
Engineering Division

Erica Rooney, P.E. City Engineer

**PERFORATED PIPE**

**SD9-11**

EFFECTIVE DATE: SEPTEMBER 14, 2020 NOT TO SCALE

DRAWING NUMBER