



NOTES:

1. MINIMUM ASPHALTIC CONCRETE LIFT THICKNESS SHALL BE 2" THEREFORE 2-2" LIFTS ARE TYPICAL.
2. COMPACTION REQUIREMENTS: SUBGRADE SOIL AND CRUSHED ROCK, 95% ASTM D1557; ASPHALTIC CONCRETE, 92% ODOT TM 305.
3. 1' GRAVEL SHOULDER ADJACENT TO SWALE OR 3' GRAVEL SHOULDER ADJACENT TO DITCH. AS DIRECTED BY CITY ENGINEER.



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

20 FT. & 28 FT. LOCAL
STREET SECTION

S1-01

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER