



NOTES:

- 1) ALL POURED IN PLACE CONCRETE SHALL HAVE A 28 DAY STRENGTH OF 3,000 P.S.I.
- 2) STEEL TO BE NEW STRUCTURAL STEEL, ASTM A-7, A-36, OR A-373.
- 3) USE SLANTED OR BOX FRAME AND GRATE AS REQUIRED BY CITY. SEE DETAIL SD6-01B AND SD6-01C
- 4) MINIMUM SUMP DEPTH IS 24" TYPICAL, 36" MINIMUM SUMP DEPTH IF FITTED WITH A SNOOT



City of Lake Oswego
Engineering Division
Erica Rooney, P.E. City Engineer

STANDARD DITCH INLET

SD6-01A

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER