



NOTES: 1. FOLLOWING GALVANIZING PREPARE AND PAINT EXTERIOR SURFACE OF STANDPIPE IN ACCORDANCE WITH THE PAINT MANUFACTURERS RECOMMENDATIONS AND THE FOLLOWING: SURFACE PREPARATION EXTERIOR SURFACES: SSPC-SP3 PRIME COAT: 3-5 MILS TNE MEC SERIES 27 F.C. TYPOXY OR APPROVED EQUAL. TOP COAT: 3-4 MILS TNE MEC SERIES 73, OR APPROVED EQUAL. COLOR AS SELECTED BY OWNER.



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

STANDPIPE

W3-01B

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER