



NOTES:

- 1) METER BOXES LOCATED IN TRAFFIC OR NON-TRAFFIC AREAS SHALL BE ARMORCAST A600458SA WITH MOUSE HOLE (12"x 20"x 12") AND WATER METER LID NICOR READ-RITE POLYMER B12NLGRYWATERSIGthN9
- 2) CITY VALVE SHALL BE FORD METER BOX CO.-ANGLE KEY METER VALVE-KV23-444W-NL (FLARE).
- 3) NEAREST WATER METER BOX EDGE SHALL BE INSTALLED AT LEAST 24 INCHES FROM THE SIDE LOT PROPERTY LINE.
- 4) WATER METER BOXES SHALL BE INSTALLED BACK OF SIDEWALK, UNLESS APPROVED BY CITY ENGINEER.
- 5) INSTALL WATER SERVICE NO CLOSER THAN 18 INCHES FROM WATER MAIN PIPE JOINT.
- 6) WATER MAIN SERVICE CONNECTIONS SHALL HAVE A MINIMUM OF 18 INCHES SPACING.
- 7) ALL FITTINGS SHALL BE BRASS AND MEET CURRENT AWWA SPECIFICATIONS.
- 8) ALL WATER SERVICES SHALL BE INSTALLED PRIOR TO PUBLIC MAIN PRESSURE TESTING.
- 9) INSTALL METER BOX AT TIME OF WATER SERVICE INSTALLATION.



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

1" WATER SERVICE ASSEMBLY

W1-01A

EFFECTIVE DATE: APRIL 2023

NOT TO SCALE

DRAWING NUMBER