



NOTES:

- 1) CORP. STOP, COPPER TUBING, CURB STOP, BRASS PIPING, STEEL PIPING & FITTINGS TO EQUAL SIZE OF AIR VALVE INLET/OUTLET.
- 2) CORP. STOP AND CURB STOP SHALL BE FLARED FITTINGS.
- 3) ENSURE ACCESS TO CURB STOP.
- 4) SEE DETAIL W3-01B FOR MORE INFORMATION ABOUT BRASS STAND PIPE AND CONCRETE FOUNDATION
- 5) FOR USE ON 8" AND SMALLER DIAMETER WATER MAINS



City of Lake Oswego
Engineering Division

Erica Rooney, P.E. City Engineer

AIR VALVE ASSEMBLY

W3-01A

EFFECTIVE DATE: APRIL 2023

NOT TO SCALE

DRAWING NUMBER