



NOTES:

- 1) PAINT EXTERIOR SURFACE OF STANDPIPE IN ACCORDANCE WITH THE PAINT MANUFACTURERS RECOMMENDATIONS AND THE FOLLOWING: SURFACE PREPARATION EXTERIOR SURFACES: SSPC-SP3 PRIME COAT: 3-5 MILS TNEMEC SERIES 27 F.C. TYPOXY OR APPROVED EQUAL. TOP COAT: 3-4 MILS TNEMEC SERIES 73, OR APPROVED EQUAL. COLOR AS SELECTED BY OWNER
- 2) FITTINGS AND PIPE TO EQUAL SIZE OF AIR VALVE INLET AND OUT
- 3) FINALIZE LOCATION OF STAND PIPE WITH CITY INSPECTOR PRIOR TO INSTALLATION



City of Lake Oswego
Engineering Division
Erica Rooney, P.E. City Engineer

AIR VALVE STANDPIPE

W3-01B

EFFECTIVE DATE: APRIL 2023

NOT TO SCALE

DRAWING NUMBER