



NOTES:

- 1) VALVE BOXES SHALL BE CENTERED DIRECTLY OVER THE VALVE NUT IN A VERTICAL POSITION.
- 2) VALVE BOX TOP SHALL BE ADJUSTED TO MEET FINISHED GRADE.
- 3) VALVES 8" AND SMALLER SHALL BE MJ GATE VALVES. VALVES 12" AND LARGER SHALL BE MJ BUTTERFLY VALVES.
- 4) WRAP VALVE WITH V-BIO POLYETHYLENE ENCASUREMENT PRIOR TO BACKFILLING. EXTEND POLYETHYLENE 6" MINIMUM BEYOND VALVE AND SECURE TO PIPE WITH 10 MIL PVC TAPE.
- 5) CENTER NUT IN PIPE. OPERATOR EXTENSION AND ROCK GUARD REQUIRED WHEN VALVE NUT IS DEEPER THAN 6 FEET FROM FINISH GRADE.



City of Lake Oswego
Engineering Division
Erica Rooney, P.E. City Engineer

TYPICAL VALVE SETTING

W6-01

EFFECTIVE DATE: APRIL 2023

NOT TO SCALE

DRAWING NUMBER